

**IOWA DEPARTMENT OF NATURAL RESOURCES
NPDES REPORTING SYSTEM - MONTHLY OPERATION REPORT
FACILITY INFORMATION**

Facility Name: SIOUX CITY, CITY OF STP

NPDES #: 9778001

Month/Year: 11/2016

OUTFALL #(s): IC-00 - 001 - DISCHARGE FROM AN ACTIVATED SLUDGE WASTEWATER TREA


Operator Name: James Maynes

Certification #: 6232

Phone #: 712-279-6113

Lab Certification #: 323

Comments: On 11/1/2016, lab transitioned to computer calculations utilizing Hach/Wims for BOD, TSS, and TS/VS. On 11/23/2016, a valve in the digester complex failed, allowing approximately 140,000 gallons of raw sludge to directly enter the aeration basins. Tom Roos was notified & corrective action was taken, however higher than normal final effluent TSS occurred for at least 3 days.
* Note the Comments holds 255 characters. For longer Comments please attach them to the E-mail

Signature: 

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.